

Attempt To Repair

00-20000192

HARNETT COUNTY HEALTH DEPARTMENT

No 17831

IMPROVEMENT PERM

Attempt To Repair

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Carole Davis Real Est / Mike House New Installation Septic Tank
Property Location: SR# NC 27 Repairs Nitrification Line
230 Lake Ridge Dr Cameron NC 28326
Subdivision MIRC BRANCH Lot # 91

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 (existing) Lot Size: 150 x 175 x 150 x 175

Basement with Plumbing: Garage: MUST meet onsite

Water Supply: Well Public Community MUST Re Route UNDER Ground

Distance From Well: 50 ft. utilities

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Pump to Conventional


Size of tank: Septic Tank: existing gallons Pump Tank: 1000 gallons

Subsurface Drainage Field No. of 3 exact length 60 ft. width of 3 ft. depth of 18 in. variable

French Drain Required: _____ Linear feet

This is an attempt to repair a failing septic system Date: 5-8-2000

This permit is subject to revocation if site plans or intended use change. Signed: JOR LANS Environmental Health Specialist



No Authorization To construct To be Issued until I meet Installer on site