

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Tom Humphries

[X] New Installation [] Septic Tank

Property Location: SR# 1418 OAKRIDGE RIVER

[X] Repairs [X] Nitrification Line

Subdivision Oakridge Bluffs Lot # 2

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 3.08

Basement with Plumbing: [] Garage: []

Water Supply: [] Well [X] Public [] Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [X] Conventional [X] Other EEE-ZZZ LAY I WWS- 953R

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 1 exact length of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-20 in.

French Drain Required: _____ Linear feet

Date: 12-4-00

This permit is subject to revocation if site plans or intended use change.

Signed: James C. Markant III R.S. Environmental Health Specialist

IF NOT ABLE TO INSTALL CONTACT HRHD FOR REPERMITTING.

