

01-20000378

HARNETT COUNTY HEALTH DEPARTMENT

No 17555

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Kevin Lanthier  New Installation  Septic Tank  
Property Location: SR# 1441 Chaleybeate Springs Rd  Repairs  Nitrification Line

Subdivision Cross Link Lot # 10

Tax ID # \_\_\_\_\_ Quadrant # \_\_\_\_\_

Number of Bedrooms Proposed: 3 Lot Size: \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other Polystyrene Aggregate Trench System I NWS-95-7R

Size of tank: Septic Tank: existing gallons Pump Tank: existing gallons

Subsurface Drainage Field No. of ditches 4 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 18-24 in.


French Drain Required: \_\_\_\_\_ Linear feet

Date: 1/31/2001

This permit is subject to revocation if site plans or intended use change.

Signed: Dwight M. Lewis  
Environmental Health Specialist

- \* Maintain setbacks
- \* Use stepdowns if needed
- \* Connect Existing Drain Lines to New Drain Lines using a "Bull Run Valve"
- \* Replace "Sanitary Tee" in septic tank w/ New Tee + Filter



HARNETT COUNTY HEALTH DEPARTMENT  
AUTORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 17555. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent \_\_\_\_\_

Name: Kevin Linticom Telephone # 919-639-7718

Address: 474 Cross Link Dr. Angier, N.C. 27501

Property Location: SR # 1441 Road Name Chalabante Springs

New Installation \_\_\_\_\_ Repair  Septic Tank \_\_\_\_\_ Nitrification Lines

Subdivision Cross Link Lot # 10

Number of Bedrooms Proposed: Existing Lot size: \_\_\_\_\_

Basement \_\_\_\_\_ With Plumbing \_\_\_\_\_ Without Plumbing \_\_\_\_\_

Water Supply: Well \_\_\_\_\_ Public  Minimum Well Setback: 50 ft.

Type of System: Conventional \_\_\_\_\_ Other Polystyrene Aggregate Trench System Iwws-95.32

Tank Volume: Septic Tank existing gallons Pump Chamber existing gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 4 Length of lines 80 ft

Width of ditches 3 ft. Depth of ditches 18-24 inches

French Drain: Linear feet required \_\_\_\_\_ Depth of gravel \_\_\_\_\_

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Bryan M. Swan D.S. Date: 1/31/2001