

HTE# _____

Harnett County Department of Public Health

29151

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Leigh DAVIES PROPERTY LOCATION: Hwy 27
 NEW REPAIR EXPANSION SUBDIVISION _____ LOT # _____
 Type of Structure: Ex SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 250 Reducton
 Projected Daily Flow: 240 GPD
 Number of bedrooms: 2 Number of Occupants: 4 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: James E. Mankoff Date: 11-29-16 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Leigh DAVIES PROPERTY LOCATION: Hwy 27
 SUBDIVISION _____ LOT # _____
 Facility Type: Ex SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 240 GPD
 (See note below, if applicable)

250 Reducton System (Repair)
Installation Requirements/Conditions
 Septic Tank Size 625 gallons Exact length of each trench 70 feet Trench Spacing: 9 Feet on Center
 Pump Tank Size 0A gallons Trenches shall be installed on contour at a Soil Cover: 6 inches
1000 new Maximum Trench Depth of: 20' m inches (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
 Conditions: _____ 2 inches above pipe
12 inches total

WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.

***If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.*

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Mankoff Date: 11-29-16
 Construction Authorization Expiration Date: 11-29-21

HTE# _____


Permit # 29151

Harnett County Department of Public Health Site Sketch

ISSUED TO: Leif DAVIES PROPERTY LOCATOR: Hwy 27 SUBDIVISION _____ LOT # _____

Authorized State Agent: James E. Markham Date: 11-29-16

- * Ex OR NEW Tank CAN BE USED
- * Tank Placement IS up to Contractor
- * DRAIN LINES ARE DOWN Slope from EX TANK SOIL WILL change from Clay Topsoil to sandy Topsoil AREA (about 60') DOWN Slope



Well
EX