

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Greg Faurote New Installation Septic Tank
Property Location: SR# 2045 Repairs Nitrification Line

Subdivision TRADEWINDS Lot # 68

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1/2 Acre

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: 50 min ft. *NOTE Change IN HOUSE location*

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 60 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 5-29-96

Signed: 900 WARS

Environmental Health Specialist

MUST MOVE house Back AS shown on permit -100' from front Property line
MUST KEEP DRIVEWAY AS close AS possible to Lot 69/Lot 68 property line
NO wider than 10' at the Rd at the property corner.
STUB out Plumbing shallow 24" Ditch Depth Follow contours



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 11169. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Greg Faurote

Name: _____ Telephone # _____

Address: _____

Property Location: SR # 2045 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision TRADEWINDS Lot # 68

Number of Bedrooms Proposed: 3 Lot size: 1/2 acre

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: _____ ft.

Type of System: Conventional 1000 Other _____

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 60

Width of ditches 3 ft. Depth of ditches 24 inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Jo W. RS Date: 5-29-96