

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Greg Faurote New Installation Septic Tank
Property Location: SR# 2045 Repairs Nitrification Line

Subdivision TRADEWINDS Lot # 67

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 1/2 Acre

Basement with Plumbing: Garage: NOTE Changes In

Water Supply: Well Public Community House location

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other Infiltrator JWWS-93-2-R1

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons


Subsurface Drainage Field No. of ditches 3 exact length of each ditch 54 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain required: _____ Linear feet 9 Joints Infiltrator

This permit is subject to revocation if site plans or intended use change. Date: 5-29-96

Signed: Joe Wark RS

Lot 68 Environmental Health Specialist



NOTE Changes In house location must be as shown on permit 100' from Rd Front Property Line 10' from Lot 67/Lot 66 Property Line STUB OUT Plumbing shallow 24" Ditch Depth follow contours MAINTAIN ALL Required set BACKS

HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 11170. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Greg Faurote

Name: _____ Telephone # _____

Address: _____

Property Location: SR# 2045 Road Name _____

New Installation Repair _____ Septic Tank Nitrification Lines

Subdivision TRADE WINDS Lot # 67

Number of Bedrooms Proposed: 3 Lot size: 1/2 ACRE

Basement _____ With Plumbing _____ Without Plumbing _____

Water Supply: Well _____ Public Minimum Well Setback: _____ ft.

Type of System: Conventional Other Infiltrator JWS-93-2-R1

Tank Volume: Septic Tank 1000 gallons Pump Chamber _____ gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines per Field 3 Length of lines 54
9 Joints

Width of ditches _____ ft. Depth of ditches _____ inches

French Drain: Linear feet required _____ Depth of gravel _____

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: Jr W. R. Date: 5-29-96