

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) A. J. Champion Const. New Installation Septic Tank
Property Location: Lot # 31 Clearfield Estates Repairs Nitrification Line
SR 1508, Currier

Number of Bedrooms Proposed: 3 Lot Size: .9 ac

Basement with Plumbing: Garage:
Water Supply: Well Public Community

Distance From Well: 100' + ft. any existing

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 5-28-93

Signed: [Signature]

Environmental Health Specialist

VOID AFTER 5 YEARS

