

HTE# Repair

Harnett County Department of Public Health

26173

Improvement Permit

A building permit cannot be issued with only an Improvement Permit.

PROPERTY LOCATION: 12638 NC 42 Hwy

ISSUED TO: John E. Homan

SUBDIVISION _____

LOT # _____

NEW REPAIR EXPANSION

Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: Existing Store

Proposed Wastewater System Type: pump to 25% reduction

Projected Daily Flow: 700 GPD

Number of bedrooms: _____ Number of Occupants: _____ max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well _____ feet

Permit valid for: Five years

Permit conditions: _____ No expiration

Authorized State Agent: Bryan McSwain RCHS

Date: 7/19/2010

SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: John E. Homan

PROPERTY LOCATION: 12638 NC 42 Hwy

SUBDIVISION _____

LOT # _____

Facility Type: Existing Store New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** _____ (Initial) Wastewater Flow: 700 GPD

(See note below, if applicable)

Existing System (Repair)

Installation Requirements/Conditions

Septic Tank Size 1500 gallons

Pump Tank Size _____ gallons

Number of trenches _____

Exact length of each trench _____ feet

Trenches shall be installed on contour at a

Maximum Trench Depth of: _____ inches

(Trench bottoms shall be level to +/-1/4"

in all directions)

Trench Spacing: _____ Feet on Center

Soil Cover: _____ inches

(Maximum soil cover shall not exceed

36" above the trench bottom)

Pump Requirements: _____ ft. TDH vs. _____ GPM

_____ inches below pipe

Aggregate Depth: _____ inches above pipe

Conditions: _____ inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____

Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McSwain RCHS

Date: 7/19/2010

Construction Authorization Expiration Date: 7/19/2015

HTE# Repair


Permit # 26173

Harnett County Department of Public Health Site Sketch

ISSUED TO: John E. Homen PROPERTY LOCATOR: 12638 NC 42 Hwy
SUBDIVISION _____ LOT # _____

Authorized State Agent: Gregory McSwain, REAS Date: 7/19/2020

* New tank can be placed anywhere so that plumbing to existing supply lines can be tied into New tank



Hwy 42