

SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____

DATE _____

FACTORS		PROFILES												
		1	2	3	4	5	6	7	8	9	10			
LANDSCAPE POSITION	.1940													
SLOPE (%)	.1940													
HORIZON 1 DEPTH		0-30	0-30	0-32	0-30	0-25								
Texture Group	.1941(A)(1)	LS	LS	LS	LS	LS								
Consistence	.1941	VFr	VFr	VFr	VFr	VFr								
Structure	.1941(A)(2)	G	G	G	G	G								
Mineralogy	.1941(A)(3)	NEH	NEH	NEH	NEH	NEH								
HORIZON 2 DEPTH		30-42	30-40	32-42	30-40	25-30								
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SCL	SCL								
Consistence	.1941	Fr	Fr	Fr	Fr	Fr								
Structure	.1941(A)(2)	SBR	SBR	SBR	SBR	SBR								
Mineralogy	.1941(A)(3)	SEXP	SEXP	SEXP	SEXP	SEXP								
HORIZON 3 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
HORIZON 4 DEPTH														
Texture Group	.1941(A)(1)													
Consistence	.1941													
Structure	.1941(A)(2)													
Mineralogy	.1941(A)(3)													
SOIL WETNESS	.1942													
RESTRICTIVE HORIZON	.1944													
SAPROLITE	.1943/.1956													
CLASSIFICATION	.1948	PS	PS	PS	PS	PS								
LONG TERM ACCEPTANCE RATE	.1955	0.6	0.6	0.6	0.6	0.6								

