

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:
Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Harvey Montague New Installation Septic Tank
Property Location: Benton Place Lot #33 Repairs Nitrification Line
SR 1504

Number of Bedrooms Proposed: 3 Dish Washer Garbage Disposal
Lot Size: .516 acres Water Supply: Well City Community
Distance From Well? At least 50ft

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.


Kind of Material for Tank: Concrete Other _____

Size of Tank: Capacity 900 Gallons

Subsurface No. of 2 Exact Length 100 Width of 3 Depth of 22 Inches
Drainage Field Ditches of each Ditch Ft. Ditches Ft. Ditches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 29 Sept 89
Signed: Nicholas Prince
(SANITARIAN)



- Maintain at least 50ft from all wells.
- Maintain 10ft from property lines
- Permit #4142 void upon issuance of this permit