

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) (D) Currin Builders New Installation Septic Tank
 Property Location: SR 1504 Repairs Nitrification Line
Benton Place II Lot # 39

Number of Bedrooms Proposed: 2 Dish Washer Garbage Disposal
 Lot Size: 3/4 acre Water Supply: Well City Community
 Distance From Well? 50 ft +

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank: Concrete Other _____

Size of Tank: Capacity 1000 Gallons


Subsurface Drainage Field Ditches No. of 2 Exact Length of each Ditch 100 Ft. Width of 3 Ft. Ditches Depth of 22 Ft. Ditches 22 Inches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 6/6/91

Signed: Mike Eaker
 (SANITARIAN)

Void After 5 Years



- * Maintain 10ft. from property lines
- * Install lines on contour of landscape
- * Maintain at least 50 ft. from any wells