

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No. 5805

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Russell Lamm [X] New Installation [X] Septic Tank
Property Location: off SR 1504 [] Repairs [X] Nitrification Line
Benton Place II lot #42

Number of Bedrooms Proposed: 3 Lot Size: 0.690

Basement with Plumbing: [] Garage: []
Water Supply: [X] Well [] Public [] Community
Distance From Well: 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: [X] Conventional [] Other
Size of tank: Septic Tank: 1000 gallons Pump Tank:
Subsurface No. of exact length width of depth of
ainage Field ditches 3 of each ditch 80 ft. ditches 3 ft. ditches 22 in.
French Drain required: Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 09/09/91
Signed: Charles [Signature]
Environmental Health Specialist

VOID AFTER 5 YEARS

