

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No 5835

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Currin Builders, Inc.  New Installation  Septic Tank
Property Location: off SR 1504  Repairs  Nitrification Line
Benton Place II lot #42

Number of Bedrooms Proposed: 3 Lot Size: 3/4 acre

Basement with Plumbing:  Garage: 
Water Supply:  Well  Public  Community
Distance From Well: > 50 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_
Size of tank: Septic Tank: 900 gallons Pump Tank: \_\_\_\_\_ gallons
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 20 in.
French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 10/28/91
Signed: Charles Wood Jr.
Environmental Health Specialist

VOID AFTER 5 YEARS

