

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:  
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Curcin Builders  New Installation  Septic Tank  
 Property Location: SR 1504 Benton Place II  Repairs  Nitrification Line  
Lot # 45

Number of Bedrooms Proposed: 2  Dish Washer  Garbage Disposal  
 Lot Size: 3/4 acre Water Supply:  Well  City  Community  
 Distance From Well?  60 ft. +

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:  Concrete  Other


Size of Tank: Capacity 1000 Gallons  
 Subsurface Drainage Field: No. of Ditches 2 Exact Length of each Ditch 100 Ft. Width of Ditches 3 Depth of Ft. Ditches 22 Inches

Any Change in the layout of this system without prior approval of the issuing authority will result this permit being void.

Date: 6/6/91

Signed: Mike Faka  
 (SANITARIAN)

Void After 3 Years



\* Maintain - at least 50 ft from any wells

\* Install lines on contour of hill