

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No 5917

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) W. Russell Lamm
Property Location: off SR 1504 Benton Place II #47
New Installation, Septic Tank, Repairs, Nitrification Line

Number of Bedrooms Proposed: 3 Lot Size: .735 acres

Basement with Plumbing: Garage: Water Supply: Well, Public, Community Distance From Well: 50+ ft.


Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other Pump System
Size of tank: Septic Tank: 900 gallons Pump Tank: 900 gallons
Subsurface No. of exact length width of depth of
inage Field ditches 3 of each ditch 100 ft. ditches 3 ft. ditches 18 in.
French Drain required: N/A Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 16 Jul 92
Signed: [Signature]
Environmental Health Specialist

VOID AFTER 5 YEARS



\* Shift location of house 30 ft to Right property line
\* Place D. box 25 ft from edge of road and 10 ft from left property line
\* Pump: Alarms to state specs