

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) LARRY K. ALLEN New Installation Septic Tank
Property Location: LOT 5 HIGHLAND HILLS Repairs Nitrification Line
GIBB RD

Number of Bedrooms Proposed: 3 Lot Size: .53 ACRES

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: N/A ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Capacity of tank: Septic Tank: 900 gallons Pump Tank: N/A gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75' width of ditches 3 ft. depth of ditches 24 in.


French Drain required: N/A Linear feet

This permit is subject to revocation if site plan or intended use change.

Date: 8-16-93
Signed: [Signature]

Environmental Health Specialist

VOID AFTER 5 YEARS



GIBBS COURT Rd