

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Linwood McKay New Installation Septic Tank
Property Location: SR# 1711 Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: .68ac

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100+ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 3 of each ditch 80 ft. ditches 3 ft. ditches 24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.


Date: 10-14-93

Signed: Thomas J. Boye

Environmental Health Specialist

VOID AFTER 5 YEARS

path to SR 1711



*Maintain Setbacks
5' from House
10' from property
lines*

*Conv
Repair*