

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) KilArnold Corp  New Installation  Septic Tank  
 Property Location: SR# HWY 24  Repairs  Nitrification Line  
 Subdivision Heritage Village Lot # E-11  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: W. Sharpe Registration # \_\_\_\_\_  
 Basement with Plumbing:  Garage:   
 Water Supply:  Well  Public  Community  
 Distance From Well: \_\_\_\_\_ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
 Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 120 ft. width of ditches 3 ft. depth of ditches 15 in.  
 French Drain: \_\_\_\_\_ Linear feet

Date: 9-28-95

PERMIT NO. 08649

Inspected by: J. V. ARS

Environmental Health Specialist

