

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
LANDSCAPE POSITION	L	L	L		
SLIP (%)	4	4	4		
ZON I DEPTH	0-20	0-28	0-26		
Soilure Group	LS	LS	LS		
Consistence	NFI	NFI	NFI		
Structure	SI	SI	SI		
Mineralogy	II	II	II		
ZON II DEPTH	20-42	28-38	26-38		
Soilure Group	SL	SL	SL		
Consistence	A	A	A		
Structure	MI	MI	MI		
Mineralogy	II	II	II		
ZON III DEPTH		38-47			
Soilure Group		LS			
Consistence		NFI			
Structure		SI			
Mineralogy		II			
ZON IV DEPTH					
Soilure Group					
Consistence					
Structure					
Mineralogy					
RELATIVE WETNESS	742	742	736		
RESTRICTIVE HORIZON	-	-	-		
PROLITE	-	-	-		
CLASSIFICATION	S	S	S		
LONG-TERM ACCEPTANCE RATE	0.8	0.8	0.8		

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
LANDSCAPE POSITION					
SLIP (%)					
ZON I DEPTH					
Soilure Group					
Consistence					
Structure					
Mineralogy					
ZON II DEPTH					
Soilure Group					
Consistence					
Structure					
Mineralogy					
ZON III DEPTH					
Soilure Group					
Consistence					
Structure					
Mineralogy					
ZON IV DEPTH					
Soilure Group					
Consistence					
Structure					
Mineralogy					
RELATIVE WETNESS					
RESTRICTIVE HORIZON					
PROLITE					
CLASSIFICATION					
LONG-TERM ACCEPTANCE RATE					

SITE CLASSIFICATION: _____ SITE LONG-TERM ACCEPTANCE RATE: _____
 EVALUATED BY: _____ OTHER(S) PRESENT: _____
 REMARKS: _____

SANITARY SEWAGE SYSTEM

OWNER: W. W. Bullshin PHONE: _____ DATE REQUESTED: _____ DATE EVALUATED: 6-8-83
 ADDRESS: _____ PROPERTY IDENTIFICATION NO.: _____
 COUNTY: _____ PROPERTY SIZE: _____ PROPOSED FACILITY: _____
 LOCATION OF SITE: Lot # 25 Pine Avenue Sec 3
 WATER SUPPLY: On-Site Well _____ Community _____ Public EVALUATION BY: Auger Boring Pit _____ Cut _____

LANDSCAPE POSITION	Group	TEXTURE	App. Rate	MOIST	LEGEND	STRUCTURE	MINERALOGY
				CONSISTENCE			
R - Ridge	I	s - sand	1.2-0.8	vfr - very friable	WET	sg - single grain	1:1, 2:1, mixed
S - Shoulder slope		ls - loamy sand		fr - friable		Ns - non-sticky	
L - Linear slope	II	sl - sandy loam	0.8-0.6	fl - firm	Vs - very sticky	m - massive	
FS - Foot slope		l - loam		vl - very firm		Ss - slightly sticky	
N - Nose slope	III	sl - silt	0.6-0.3	ell - extremely firm	Np - non-plastic	cr - crumb	
H - Head slope		sil - silt loam		sp - slightly plastic			
Cc - Concave slope		scl - silty clay loam		P - plastic			
Cv - Convex slope		cl - clay loam		Vp - very plastic			
T - Terrace		scl - sandy clay loam					
FP - Flood Plain		sc - sandy clay					
	IV	slc - silty clay	0.4-0.1				
		c - clay					

Use the above standard abbreviations.

NOTES:

- Horizon Depth - in inches
- Depth of Fill - in inches from land surface
- Restrictive Horizon - thickness and inches from land surface
- Saprolite - S (suitable) or U (unsuitable)

DHS 2601 (Revised _____)
 Sanitation Branch (Review _____)

NOTES:

- Soil Wetness - inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
- Classification - S (suitable), PS (provisionally suitable) or U (unsuitable)
- Long-Term Acceptance Rate - gal/day/ft²