

IMPROVEMENT PERMIT

No

6712

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) (8) Danny Norris New Installation Septic Tank
 Property Location: SR 1201 Repairs Nitrification Line
Mire Branch Subdivision Lot #19
 Number of Bedrooms Proposed: 3 Lot Size: 1 acre
 Basement with Plumbing: Garage:
 Water Supply: Well Public Community
 Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____
 Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface Drainage Field No. of ditches 2 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 24 in.
 French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 9/16/92
 Signed: Mike Eaker

VOID AFTER 5 YEARS

Lot #19

Environmental Health Specialist



SR 1201 → To Hwy 27