

# IMPROVEMENT PERMIT

No 6522

It is ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) (1) Danny Norris (Mire Branch lot #67)  New Installation  Septic Tank  
Property Location: off Hwy 27  Repairs  Nitrification Line

Number of Bedrooms Proposed: 3 Lot Size: 1+ acre

Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: \_\_\_\_\_ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.


Type of system:  Conventional  Other Pump System  
Size of tank: Septic Tank: 1000 gallons Pump Tank: 1000 gallons  
Subsurface Drainage Field No. of ditches 3 exact length of each ditch 50 ft. width of ditches 3 ft. depth of ditches 20 in.  
French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site is or intended use change.

Date: 6/24/92  
Signed: Charles H. Hood Jr.  
Environmental Health Specialist

### VOID AFTER 5 YEARS

- \* Pump, floats, alarm, NEMA 4X box installed to Harnett County Specs.
- \* Maintain 10' from property lines.



1/27/97