

HARNETT COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT

No

5996

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Danny E. Norris New Installation Septic Tank
Property Location: Hwy 27 Repairs Nitrification Line
Lot 65 in 10 Branch

Number of Bedrooms Proposed: 3 Lot Size: 1 acre

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100 ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 24 in.

rench Drain required: _____ Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 12/11/91
Signed: John H. Boyd R.S.
Environmental Health Specialist

VOID AFTER 5 YEARS

