

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:  
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Hanny Norris  New Installation  Septic Tank  
 Property Location: High 27  Repairs  Nitrification Line  
Johnsonville Lot 64 mile branch  
 Number of Bedrooms Proposed: 3  Dish Washer  Garbage Disposal  
 Lot Size: 1 acre + Water Supply:  Well  City  Community  
 Distance From Well?

Above information certified by: APP

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:  Concrete  Other \_\_\_\_\_

Size of Tank: Capacity 1000 Gallons

Subsurface Drainage Field Ditches No. of 2 Exact Length 75 Width of 3 Depth of 24  
 of each Ditch \_\_\_\_\_ Ft. Ditches \_\_\_\_\_ Ft. Ditches \_\_\_\_\_ Inches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void. THIS permit is  
 Date: 06/05/91  
 Signed: Art H. Byrd R-5 (SANITARIAN)  
 Void After 3 Years 5 Subject to revocation if site plans or intended use change.

