

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:  
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) ① Danny Norris  New Installation  Septic Tank

Property Location: Hy 27 W  Repairs  Nitrification Line

Johnsonville lot 51 mine Branch

Number of Bedrooms Proposed: 3  Dish Washer  Garbage Disposal

Lot Size: 1 acre + Water Supply:  Well  City  Community  
 Distance From Well?

Above information certified by: App.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:  Concrete  Other \_\_\_\_\_

Size of Tank: Capacity 1000 Gallons

Subsurface No. of Drainage Field Ditches 2 Exact Length of each Ditch 75 Ft. Width of Ditches 3 Depth of Ditches 18" <sup>24" OK</sup> Inches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void. Date: 06/05/91  
 Signed: April H. Byrd R.S. (SANITARIAN)

Void After 3 Years <sup>5 to revocation if site plans or intended use change.</sup>

