

IMPROVEMENT PERMIT

No 6738

As it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) WEST BUILDERS New Installation Septic Tank

Property Location: HWY 27 Repairs Nitrification Line
MIKE BRANCH LOT # 97

Number of Bedrooms Proposed: 3 Lot Size: 1 ACRE

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 900 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 2 exact length of each ditch 80 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain required: _____ Linear feet

This permit is subject to revocation if site is or intended use change.

Date: 9/28/92

Signed: Mike E. K.

Environmental Health Specialist

VOID AFTER 5 YEARS

* Stay 10ft. from any property line

