

IMPROVEMENT PERMIT

No 3555

Be it ordained by the Harnett County Board of Health as follows:

Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Rufus Anderson New Installation Septic Tank
 Property Location: Briarwood Subdivision Repairs Nitrification Line
Lot # 31 SR 1412

Number of Bedrooms Proposed: 3 Dish Washer Garbage Disposal
 Lot Size: 20,222 ft² Water Supply: Well City Community
 Distance From Well? 50 ft.

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank: Concrete Other _____

Size of Tank: Capacity 1000 Gallons
 Subsurface No. of Ditches 3 Exact Length 80 Width of 3 Depth of 22
 Drainage Field Ditches of each Ditch Ft. Ditches Inches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.
 Date: 4/20/88
 Signed: Mike Eaker
 (SANITARIAN)

After 3 Years

