

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

OWNER: HEH Const. APPLICANT: _____
 ADDRESS: Fay APPLICATION DATE: 1-24-96 DATE EVALUATED: 1-28-96
 PROPOSED FACILITY: Home PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: .37
 LOCATION OF SITE: Lot 89 Tradewinds PROPERTY RECORDED: _____
 WATER SUPPLY: Private Public Well Spring Other _____
 EVALUATION METHOD: Auger Boring Pit Cut
 TYPE OF WASTEWATER: Sewage Industrial Process Mixed

P R O F I L E #	.1940 LAND- SCAPE POSITION/ SLOPE %	HORI- ZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941)		OTHER PROFILE FACTORS				PROFILE CLASS & LTAR
			.1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	.1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	
1	0-5% L	0-48	SL Mt to Gr	VFR	40"				.8
2	0-5% L	0-10	Fill LS/SL	VFR	36"				.3 to .4
		10-15	SL Gr	VFR					
		15-48	SC sbk	F ₁					
3	0-5% L	0-16	SL Gr	VFR	24"				.3
		16-48	SC sbk	F ₁					
4	0-5% L	0-10	SL Gr	VFR	26"				.4
		10-36	SC sbk	F ₁					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM	OTHER FACTORS (.1946): _____
Available Space (.1945)	OK	OK	SITE CLASSIFICATION (.1948): <u>PS</u>
System Type(s)	Chamber conv.	conv.	EVALUATED BY: <u>Jeff Eudy</u>
Site LTAR	.3	.3	OTHER(S) PRESENT: _____

LEGEND

use the following standard abbreviations

<u>LANDSCAPE POSITION</u>	<u>GROUP</u>	<u>SOIL TEXTURE</u>	<u>CONVENTIONAL .1955 LTAR</u>	<u>LPP .1957 LTAR</u>	<u>MINERALOGY/ CONSISTENCE</u>	<u>STRUCTURE</u>
CC (Concave Slope)	I	S (Sand)	1.2 - 0.8	0.6 - 0.4	NEXP (Non-expansive) SEX ⁷ (Slightly Expansive) EXP (Expansive)	G (Single Grain)
CV (Convex Slope)		LS (Loamy Sand)				M (Massive)
D (Drainage Way)	II	SL (Sandy Loam)	0.8 - 0.6	0.4 - 0.3		CR (Crumb)
DS (Debris Slump)		L (Loam)				GR (Granular)
FP (Flood Plain)						SBK (Subangular Blocky)
FS (Foot Slope)	III	SI (Silt)	0.6 - 0.3	0.3 - 0.15		ABK (Angular Blocky)
H (Head Slope)		SICL (Silty Clay Loam)				PL (Platy)
L (Linear Slope)		CL (Clay Loam)				PR (Prismatic)
N (Nose Slope)		SCL (Sandy Clay Loam)				
R (Ridge)		SLC (Silt Loam Clay)				
S (Shoulder Slope)	IV	SC (Sandy Clay)	0.4 - 0.1	0.2 - 0.05	<u>MOIST</u> VFR (Very Friable) FR (Friable) FI (Firm) VFI (Very Firm v. Very Sticky) EFI (Extremely Firm)	<u>WET</u> NS (Non-sticky)
T (Terrace)		SIC (Silty Clay)				SS (Slightly Sticky)
		Clay/O (Organic)	S (Sticky)			
			VS (Very Sticky)			
		None	NP (Non-plastic)			
			SP (Slightly Plastic)			
			P (Plastic)			
			VP (Very Plastic)			

NOTES

- HORIZON DEPTH** In inches below natural soil surface
 - DEPTH OF FILL** In inches from land surface
 - RESTRICTIVE HORIZON** Thickness and depth from land surface
 - SAPROLITE** S(suitable) or U(unsuitable)
 - SOIL WETNESS** Inches from land surface to free water or inches from land surface to soil colors with chroma 2 or less - record Munsell color chip designation
 - CLASSIFICATION** S (Suitable), PS (Provisionally Suitable), or U (Unsuitable)
- Evaluation of saprolite shall be by pits.
 Long-term Acceptance Rate (LTAR): gal/day/ft²

Show profile locations and other site features (dimensions, reference or benchmark, and North).

