

**Improvement Permit**

A building permit cannot be issued with only an Improvement Permit

PROPERTY LOCATION: \_\_\_\_\_  
SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_

ISSUED TO: \_\_\_\_\_  
NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: \_\_\_\_\_

Proposed Wastewater System Type: \_\_\_\_\_

Projected Daily Flow: \_\_\_\_\_ GPD

Number of bedrooms: \_\_\_\_\_ Number of Occupants: \_\_\_\_\_ max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years

Permit conditions: \_\_\_\_\_  No expiration

Authorized State Agent: \_\_\_\_\_ Date: \_\_\_\_\_ SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

**Construction Authorization**

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Richard Civic PROPERTY LOCATION: 501 FLYNN McPHERSON RD  
SUBDIVISION CAMERON LOT # 841

Facility Type: EXT. SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* \_\_\_\_\_ (Initial) Wastewater Flow: \_\_\_\_\_ GPD

(See note below, if applicable )

(Repair)

**Installation Requirements/Conditions**

Septic Tank Size \_\_\_\_\_ gallons Exact length of each trench \_\_\_\_\_ feet Trench Spacing: \_\_\_\_\_ Feet on Center

Pump Tank Size \_\_\_\_\_ gallons Trenches shall be installed on contour at a Soil Cover: \_\_\_\_\_ inches

REPLACE D-BOX ADD Maximum Trench Depth of: \_\_\_\_\_ inches (Maximum soil cover shall not exceed

COVER T- END OF LINE (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe

Aggregate Depth: \_\_\_\_\_ inches above pipe

Conditions: ATTEMPT TO REPAIR DAMAGE FROM A MALFUNCTIONING \_\_\_\_\_ inches total

WASHING MACHINE. LINES APPEAR TO HAVE BEEN HYDRAULICALLY OVERLOADED. MACHINE

REPAIR AND WATER FLOW

NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. RETURNED TO NORMAL

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.**

**NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: \_\_\_\_\_ Date: 1/25/17

Construction Authorization Expiration Date: 1/25/22