

Attempt to Repair

HARNETT COUNTY HEALTH DEPARTMENT

No 15638

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Billy Dickens
Property Location: SR# HWY 421 N 5859 421 N
New Installation, Septic Tank, Repairs, Nitrification Line

Subdivision Lot #

Tax ID # Quadrant #

Number of Bedrooms Proposed: 2 existing Lot Size: 4.0 ac

Basement with Plumbing: Garage: Place filter in Tank

Water Supply: Well, Public, Community

Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional, Other

Size of tank: Septic Tank: existing gallons Pump Tank: gallons

Subsurface Drainage Field: No. of ditches 1 exact length 200 width of ditches 3 depth of ditches 18 1/2 in.

French Drain Required: Linear feet

Date: 7-1-99

This permit is subject to revocation if site plans or intended use change.

Signed: J. W. [Signature] Environmental Health Specialist

