

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) K. N. Nodd Corp New Installation Septic Tank
Property Location: SR# HWY 24 Repairs Nitrification Line

Subdivision Hickory Village Lot # E-70

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 19,309 sq ft

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: _____ ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 100 ft. width of ditches 3 ft. depth of ditches 18 in.

French Drain required: _____ Linear feet


This permit is subject to revocation if site plans or intended use change.

Date: 11-27-95

Signed: J. W. A. R. S.

Environmental Health Specialist

VOID AFTER 5 YEARS



HARNETT COUNTY HEALTH DEPARTMENT

AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 10740. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent KilArnold Corp

Name: K. Arnold Corp Telephone #

Address: 5004 Independence Way Cameron NC 28326

Property Location: SR# HWY24 Road Name HWY24

New Installation X Repair Septic Tank X Nitrification Lines Y

Subdivision Heritage Village Lot #

Number of Bedrooms Proposed: 3 Lot Size: 20,000 sq ft plus

Basement N/A With Plumbing Without Plumbing

Water Supply: Well Public X

Minimum Well Setback: 50 min ft.

Type of System: Conventional Other

Tank Volume: Septic Tank 1000 gallons, Pump Chamber gallons

Nitrification Field Specifications

Number of fields 1 Number of Lines Per Field 3 Length of Lines 100

Width of Ditches 3 ft. Depth of ditches 18 inches

Trench Drain: Linear feet required Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent of Harnett County Health Department

Name: Joe W. RS Date: 11-30-95

Must meet on site Before Installing