

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) William G Jolly New Installation Septic Tank
Property Location: SR# OAK GROVE CHURCH Repairs Nitrification Line
road

Subdivision Next to Homestead Lot # -

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: 1.9 acres

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Neighbors well

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of 4 exact length 75' width of 3 depth of as shallow as possible
ditches 3 of each ditch 100 ft. ditches 3 ft. ditches 15 possible in.
French Drain required: _____ Linear feet 15-24*


This permit is subject to revocation if site plans or intended use change.

Date: 1-24-96

Signed: James E. Mantel

Environmental Health Specialist

VOID AFTER 5 YEARS



* ORIGINAL tank can be used if structure is sound - (new lids, new tee, whatever). IF NOT sound, pull tank and use new one.
* Maintain all setbacks
* Stay off of all wells

SR 1532