

PROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Joseph Johnston New Installation Septic Tank
Property Location: SR# 1235 Adcock rd Repairs Nitrification Line

Attempt To Repair

Subdivision _____ Lot # _____

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 4 Lot Size: 1.0 AC

Basement with Plumbing: Garage: **NOTE: Set new tank shallow change plumbing in the house IF that is not possible a pump tank & pump will be required**
Water Supply: Well Public Community
Distance From Well: 50 min ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 1 exact length of each ditch 400 ft. width of ditches 3 ft. depth of ditches 18 in.
French Drain Required: _____ Linear feet

Date: 3-30-98
Signed: Joe Wain
Environmental Health Specialist

This permit is subject to revocation if site plans or intended use change.

NOTE: meet on site set new tank shallow 18" ditch follow contours

