

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION
APPLICATION FOR IMPROVEMENT PERMIT

6/15/94

DATE 6-9-94

NAME Gary Webb TELEPHONE NO. 892-8835

ADDRESS (current) Rt 2 Dunn

PROPERTY OWNER Gary Webb

SUBDIVISION NAME _____ LOT NO. _____

PROPERTY ADDRESS Rt 2 Dunn STATE ROAD NO. Mixon Rd.

DO YOU HAVE A LEGAL DEED TO THIS PROPERTY? YES NO _____

IF NO EXPLAIN _____

DIRECTIONS Go to Sadler Truck stop, go across I-95 first road to right, go straight to Webb's Estates, beside apt.

SIZE OF LOT OR TRACT 1.6

1. Type of dwelling DW ~~Basement with plumbing~~ Basement with plumbing
2. Number of Bedrooms 3 ~~2~~ Garage _____
3. Dishwasher _____
4. Garbage Disposal _____

WATER SUPPLY - PRIVATE WELL _____ COMMUNITY SYSTEM _____ COUNTY

A plot plan must be attached to this application showing: 1) Setting of dwelling, 2) Desired placement of septic tank system and 3) well placement.

Place stakes at the exact location of dwelling and at each corner of lot.

An on site inspection must be made, which consists of a soil evaluation.

A zoning permit must be obtained from the Planning Department before an improvement permit can be issued by this department.

This certifies that all the above information is correct to the best of my knowledge and any false information will result in the denial of permit. Once the permit is issued, the permit is good for a period of 5 years. The permit is subject to revocation if site plans or the intended use change.

Signature Gary Webb

County of Harnett

DEPARTMENT OF PLANNING ZONING PERMIT

No 2986

Date 9 Jun 94

Owner GARY WEBB

Address: RT 2 Box 113 Dunn NC 28334

Zoning District: RA-20M

Use Classification: D.W. MANUFACTURED HOME

Permit Number: _____

Provided the person accepting this permit shall in every respect conform to the terms of the application on file in the Zoning Administrator's office and to the provisions of the Statutes and Ordinances regulating development in Harnett County. Any VIOLATION of the terms above stated immediately REVOKES this PERMIT.

NOTICE: This structure is not to be occupied until a CERTIFICATE OF OCCUPANCY is issued by the Building Official.

PERMIT EXPIRES SIX MONTHS FROM DATE OF ISSUANCE.

PLANNING DEPARTMENT
893-7525

SANITARY SEWAGE SYSTEM

OWNER: GARY WEBB PHONE: _____ DATE REQUESTED: _____ DATE EVALUATED: 6/18/84
 ADDRESS: _____ PROPERTY IDENTIFICATION NO.: _____
 COUNTY: _____ PROPERTY SIZE: _____ PROPOSED FACILITY: _____
 LOCATION OF SITE: _____
 WATER SUPPLY: On-Site Well _____ Community _____ Public EVALUATION BY: Auger Boring PR _____

LANDSCAPE POSITION	GROUP	TEXTURE	App. Rate
R - Ridge	I	s - sand	1.2-0.8
S - Shoulder slope		lg - lamy sand	
L - Linear slope	II	sl - sandy loam	0.8-0.6
S - Foot slope		l - loam	
N - Nose slope	III	sl - silt	0.6-0.3
H - Head slope		sil - silt loam	
Cc - Concave slope		sicl - silty clay loam	
Cv - Convex slope		cl - clay loam	
T - Terrace	IV	scf - sandy clay loam	0.4-0.1
P - Flood Plain		sc - sandy clay	
		sic - silty clay	
		c - clay	

LEGEND

MOIST	CONSISTENCE	WET	STRUCTURE
vt - very friable		Ns - non-sticky	sg - single grain
fr - friable		Ss - slightly sticky	m - massive
fl - firm		S - sticky	cr - crumb
vfl - very firm		Vs - very sticky	gr - granular
eff - extremely firm			sbk - subangular blocky
		Np - non-plastic	abk - angular blocky
		Sp - slightly plastic	pl - platy
		P - plastic	pr - prismatic
		Vp - very plastic	

Use the above standard abbreviations.

- UNITS:**
 Depth - in inches
 Depth of Fill - in inches from land surface
 Thickness of Horizon - thickness and inches from land surface
 Profile - S (suitable) or U (unsuitable)

- NOTES:**
 Soil Wetness - inches from land surface to free water or inches from land surface to soil color
 Chroma 2 or less - record Munsell color chip designation
 Classification - S (suitable), PS (provisionally suitable) or U (unsuitable)
 Long-Term Acceptance Rate - gal/day/ft²

IS 2501 (Revised _____)
 Division Branch (Review _____)

FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
ESCAPE POSITION	0.55				
PE (%)	0-20%				
IZON I DEPTH	0-14"				
ure Group	II SL				
sistence	V.R.				
cture	JN				
eralogy	1:1				
IZON II DEPTH	14" 36"				
ure Group	III SCL				
sistence	FR				
cture	SB				
ralogy	1:1				
ZON III DEPTH					
ure Group					
sistence					
cture					
ralogy					
ZON IV DEPTH					
ure Group					
sistence					
cture					
ralogy					
WETNESS	moisture of 5 chona 2 36"				
RICTIVE HORIZON					
OLITE					
SIFICATION	PS				
TERM	.4				
PANCE RATE					


FACTORS	PROFILE 1	PROFILE 2	PROFILE 3	PROFILE 4	PROFILE 5
ESCAPE POSITION					
PE (%)					
IZON I DEPTH					
ure Group					
sistence					
cture					
ralogy					
IZON II DEPTH					
ure Group					
sistence					
cture					
ralogy					
IZON III DEPTH					
ure Group					
sistence					
cture					
ralogy					
IZON IV DEPTH					
ure Group					
sistence					
cture					
ralogy					
WETNESS					
RICTIVE HORIZON					
OLITE					
SIFICATION					
TERM					
PANCE RATE					

CLASSIFICATION: PS
 TESTED BY: Robert B. Sulcher, RD
 SITE LONG-TERM ACCEPTANCE RATE: .4
 OTHER(S) PRESENT:
 re. 24" trench depth due to moisture of 5 chona 2 #36"

I, JONAS E. JORDAN, CERTIFY THAT THIS PLAN WAS DRAWN UNDER MY SUPERVISION FROM AN ACTUAL SURVEY MADE UNDER MY SUPERVISION (THEY DESCRIBE THE BOUNDARIES NOT SHOWN AND CLEARLY INDICATED AS DRAWN FROM INFORMATION FOUND IN BOOK _____ PAGE _____ THAT THE RATIO OF PRECISION AS CALCULATED IS 1: _____; THAT THIS PLAN WAS PREPARED IN ACCORDANCE WITH G.S. 47-28 AS HEREBY WITNESSED BY ORIGINAL SIGNATURE, REGISTRATION NUMBER AND SEAL THIS 29 DAY

PLAT PLAN FOR
WEBB BUILDERS

N.C.S.R. 1807 60' RW



GARY WEBB

GARY WEBB

GARY WEBB

LOCATION MAP



SITE PLAN APPROVAL
District RA-20M Use Duplex & D.W.M.H.
Bedrooms 7 (2 SEPAR. TANKS)
Date 9 June 54 J. Taylor
Zoning Administrator

NORTH REF. DE. 914, PG. 87-88