

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Anthony Harrison New Installation Septic Tank
Property Location: SR# off of Marks Rd Repairs Nitrification Line

along Military Boundary Rd - on the left Turn At Rt 3 Box 198E

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: _____

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other N/A

Size of tank: Septic Tank: 1000 gallons Pump Tank: N/A gallons

Subsurface No. of exact length width of depth of
Drainage Field ditches 1 of each ditch 200 ft. ditches 3 ft. ditches 18 in.

French Drain required: N/A Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 8-8-94

Signed: Joe Waters

Environmental Health Specialist

VOID AFTER 5 YEARS

