

HARNETT COUNTY  
DEPARTMENT OF PUBLIC HEALTH

HENRY S. THOMPSON, M.P.H.  
HEALTH DIRECTOR

701 MAIN STREET  
P.O. BOX 09  
LILLINGTON, N.C. 27548-0009  
TELEPHONE: 919-893-7550  
FAX: 919-893-9429

BRANCH OFFICE ALSO AT:  
904 WEST EDGERTON STREET  
DUNN, N.C. 28335-0491  
TEL: 919-892-2424  
FAX: 919-891-4171

WRITTEN REPORT AND NOTIFICATION OF AN IMPROVEMENTS  
PERMIT DENIAL

1. Name of Applicant: Eldridge E. Williams Phone: 365 3072  
Address: \_\_\_\_\_
2. Name of Property Owner: SAME  
Phone: \_\_\_\_\_  
Address: SAME
3. Location of denied lot/site/tract: (Specific directions)  
intersection SR 1224 & 1222
4. Property Size: ? or Area: \_\_\_\_\_ sq.ft.
5. On 6-25-94 the above referenced lot was evaluated by an Environmental Health Specialist from the Harnett County Health Department. The purpose of this evaluation was to determine the suitability of the site to accept subsurface sewage disposal. The site evaluation included the following unsuitable characteristics:
  - \_\_\_ unsuitable topography and landscape position (.1940)
  - \_\_\_ unsuitable soil characteristics - texture, structure, mineralogy (.1941)
  - \_\_\_ soil wetness condition (.1942)
  - \_\_\_ inadequate soil depth (.1943)
  - \_\_\_ restrictive horizons (.1944)
  - inadequate space (.1945)
  - \_\_\_ other
6. Suggested Modifications or Alternatives (if available):  
Relocate MH obtain property next door

7. The State Sewage Disposal Rules do provide an additional option to you for consideration. Section 1957c states that a site may be used for a ground absorption sewage treatment and disposal system if written documentation including engineering, hydrogeologic, geologic, or soil studies, indicate that a proposed system can reasonably be expected to function satisfactorily.

The substantiating data from these studies must indicate that:

- A. The effluent (sewage) will receive adequate treatment.
- B. The effluent (sewage) will not contaminate ground water or surface water.
- C. The effluent (sewage) will not be exposed on the ground surface or be discharged to surface waters where it could come into contact with people, animals, or vectors.

It is the responsibility of the owner, developer, or contractor to obtain someone with a demonstrated knowledge in engineering, hydrogeologic, geologic, and soil studies to conduct these studies. The data from these studies must be forwarded to the N.C. Department of Environment, Health and Natural Resources, Division of Environmental Health for evaluation.

8. Additionally, in compliance with Chapter 130A you have a right to an informal review by the Department of Environment, Health and Natural Resources State Soil Specialist, the right to appeal under G.S. 130A-24, and to have the appeal held in the county in which the site for which the Improvements Permit was requested is located. A copy of the petition form will be provided to you if requested. It must be filed within 60 days.

If you have any questions or comments, you are encouraged to call or write this department.

6-25-94  
Date

Wayne Stewart R.S.  
Harnett County Health Department  
Environmental Health Specialist