



HARNETT COUNTY

DEPARTMENT OF PUBLIC HEALTH

TELEPHONE: 910-893-7550
FAX: 910-893-9429

A. WAYNE RAYNOR, MPH
DIRECTOR

DATE: October 15, 1997

TO: Glen Carter

FROM: Thomas J. Boyce, Soil Scientist
Harnett County Health Department

Re: Sarah Clark Property

Based on a site evaluation conducted on October 14, 1997, Ms. Clark's septic system can be relocated to the front yard adjacent to SR 1120. The system would comprise of a 1000 gallon septic tank and a 1000 gallon pump and 270 total linear feet of drainline. The well next to the right of way would have to be properly abandoned and the new system would require at least six inches of cover.

If you have any questions, I can be reached at 910-893-7547, Monday-Friday, from 8:00 -9:00 a.m.