

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Leroy Norris Jr New Installation Septic Tank
Property Location: SR# 1703 Red Hill Church Road Repairs Nitrification Line

Subdivision _____ Lot # _____

Tax ID# _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 3.24 ACRES

Basement with Plumbing: Garage:

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 15' width of ditches 3 ft. depth of ditches 18-22 in.

French Drain required: - Linear feet

This permit is subject to revocation if site plans or intended use change.

Date: 9-21-95

Signed: James E. Mantel

Environmental Health Specialist

VOID AFTER 5 YEARS

