

HTE# _____

Harnett County Department of Public Health

25136

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: OMA O'CONNELL PROPERTY LOCATION: Hwy 42
 SUBDIVISION _____ LOT # _____
 NEW REPAIR EXPANSION
 Type of Structure: EXISTING SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% REDUCTION
 Projected Daily Flow: 360 GPD
 Number of bedrooms: 3 Number of Occupants: 6 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100' feet Permit valid for: 30 DAYS
 Five years
 No expiration
 Permit conditions: _____

Authorized State Agent: James E. Manhart Date: 3-31-09 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: OMA O'CONNELL PROPERTY LOCATION: Hwy 42
 SUBDIVISION _____ LOT # _____
 Facility Type: EXISTING SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** _____ (Initial) Wastewater Flow: 360 GPD
 (See note below, if applicable)

25% REDUCTION SYSTEM (Repair)
Installation Requirements/Conditions
 Septic Tank Size 1000 gallons Number of trenches 3
 Pump Tank Size _____ gallons Exact length of each trench 100 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 24" MAX inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: SET TANK 100' MINIMUM OFF OF ALL WELLS
DRAIN LINES 100' OFF OF ANY EXISTING WELLS
12 inches total

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Manhart Date: 3-31-09
 Construction Authorization Expiration Date: 3-31-09

HTE# _____

Permit # 25136

Harnett County Department of Public Health Site Sketch

ISSUED TO: OMA O'CONNELL SUBDIVISION _____ LOT # _____

PROPERTY LOCATOR: HWY 42

Authorized State Agent: James S. Mahant Date: 3-31-09

* STAY 100' OFF OF ALL WELLS
EVEN WITH SEPTIC TANK (100' OFF OF ALL WELLS)

* 2 OR 3 DRAIN LINES CAN BE USED.

* ALL EXISTING DRAINS TO BE
TURNED INTO NEW SEPTIC TANK.

