

Health Dept Copy

VETERANS ADMINISTRATION
REPORT OF INSPECTION, INDIVIDUAL WATER SUPPLY AND SEWAGE-DISPOSAL SYSTEM

(TOP SECTION TO BE FILLED IN BY VA.)

REGIONAL OFFICE		Veterans Administration 301 North Main Street Winston-Salem, N. C.	
NAME OF BUILDER		WELCO Contractors, Inc. P. O. Box 766 Spring Lake, N. C. 28390	
PROPERTY ADDRESS	NAME OF LENDER	IF YES, HOW MANY?	SEWAGE DISPOSAL BY
6530 Azalea Drive Spring Lake, N. C. 28390	Stockton, White & Company P. O. Box 1268 Rayetteville, N. C. 28302		WATER SUPPLY BY
SUBDIVISION NAME	CASE NO.	TYPE OF INSTALLATION	WATER SUPPLY AND SEWAGE DISPOSAL (Check)
Rolling Springs	222760	NEW <input checked="" type="checkbox"/> EXISTING <input type="checkbox"/>	PUBLIC <input type="checkbox"/> COMMUNITY <input type="checkbox"/> INDIVIDUAL <input type="checkbox"/>
BLOCK NO.	LOT NO.	TOTAL NUMBER	
	11	LIVING UNITS	1
		BEDROOMS	3
		BATHS	1 1/2
CAN ATTIC OR OTHER AREA BE MADE INTO		BASEMENT	ADDITIONAL BEDROOMS?
<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO

INSTRUCTIONS: If new installation, inspect for compliance with approved exhibits and record any observed information not shown on, or which varies from, the approved exhibits. If existing installation, furnish as much of the information as may be available. As applicable use inspector's sketch on reverse.

INDIVIDUAL WATER SUPPLY SYSTEM

Distance to nearest public water main, 8 mi. feet. Size of main, _____ inches.
 Individual wells are are not customary in neighborhood.
 Give most recent record of failure of wells in immediate vicinity to furnish adequate supply of water _____

Properties in neighborhood are are not being developed with both individual water-supply and sewage-disposal systems.

Lot size: 85 feet wide, 139.69 feet deep. Dwelling set back from front property line, 35 feet.

Individual water supply from: Drilled well. Driven well. Dug well. Bored well.

Distance of well from:

Building foundation, _____ feet; nearest lot line at _____ front, _____ side, _____ rear, _____ feet;

cast iron sewer, _____ feet; tile sewer, _____ feet; septic tank, _____ feet; disposal field, _____ feet;

seepage pit, _____ feet; cesspool, _____ feet; other sources of possible pollution, _____ feet.

Well construction:

Community supply approved

Diameter, _____ inches. Total depth, _____ feet. Type of casing, _____ feet. Depth of casing, _____ feet.

Approximate depth of pumping level of water in well, _____ feet. Approximate yield, _____ gallons per minute.

Sealed watertight to depth of _____ feet.

Exterior space around casing sealed with: Cement grout. Puddled clay. Ordinary backfill.

Well cover: Concrete. Wood. Metal. Openings in well cover watertight: Yes. No.

Pump: Shallow well. Deep well. Length of drop pipe, _____ feet. Pump capacity, _____ gallons per minute.

Located in: Basement. Pump room off basement. Pump house above ground. Pump pit.

Pump room properly drained: Yes. No. Pump mounting watertight: Yes. No.

Type of storage: Pressure. Gravity. Capacity, _____ gallons.

Has bacteriological examination of water been made? Yes. No. If answer is "yes," give date _____, 19____.

Quality of water is is not satisfactory for human consumption.

Installation does does not comply with approved exhibits, if any.

INDIVIDUAL SEWAGE-DISPOSAL SYSTEM

PRIMARY TREATMENT consists of Septic tank. Cesspool.

Septic tank:

Distance from well, 1000+ feet. Material, concrete. Number of compartments, 1

Total liquid capacity, 900 gallons. Capacity inlet compartment, 900 gallons.

Cesspool: Inside length, 8' 10". Inside width, 3' 6". Liquid depth, 4' 4".

Distance from well, _____ feet; foundation, _____ feet; nearest lot line at _____ front, _____ side, _____ rear, _____ feet.

Inside diameter, _____ feet. Depth, _____ feet. Liquid capacity, _____ gallons. Lining material, _____

SECONDARY TREATMENT consists of Distribution box and Tile disposal field. Seepage pits. Other _____

Tile disposal field:

Distance from well, 1000+ feet; foundation, 20 feet; nearest lot line at _____ front, _____ side, _____ rear, 15 feet.

Total length of tile lines, _____ feet. Number of lines, 660. Distance between lines, _____ feet.

Total effective absorption area in bottom of trenches, _____ square feet. Trench width, 72 inches.

Length of each line, 110 feet. Depth, top of tile to finish grade, 18 inches.

Type of filter material: Gravel. Broken stone. Cinders. Other _____

Depth of filter material beneath tile, 4 inches. Depth of filter material over tile, 2 inches.

Seepage pits:

Number of pits, _____

Outside diameter, _____ feet. Depth, _____ feet. Lining material _____

ms. 10-17-73
Signed 12-4-73

PROJ

Wellco Contractors, Inc.

Lot #11, Olde Farm Rolling Springs, Spring Lake, N. C. 2839

3

11,856

X

900

3" 3"
in 30 minutes

1

720

120

72

X

X

Community Supply approved

Harnett County

April 24, 1973

M. H. Canady
Sanitarian II

11

W. H. Carver