

## VETERANS ADMINISTRATION REPORT OF INSPECTION, INDIVIDUAL WATER SUPPLY AND SEWAGE-DISPOSAL SYSTEM

(TOP SECTION TO BE FILLED IN BY VA.)

REGIONAL OFFICE Veterans Administration 301 North Main Street Winston-Salem, North Carolina			PROPERTY ADDRESS 6620 Azalea Drive Spring Lake, N. C. 28390			SUBDIVISION NAME Rolling Springs				
NAME OF BUILDER Wellco Contractors, Inc. P. O. Box 766 Spring Lake, N. C. 28390			NAME OF LENDER First Atlantic Corporation P. O. Box 3362 Fayetteville, N. C. 28305			BLOCK NO.		LOT NO. 136		
TOTAL NUMBER			BASEMENT		CAN ATTIC OR OTHER AREA BE MADE INTO ADDITIONAL BEDROOMS?		IF YES, HOW MANY?		WATER SUPPLY AND SEWAGE DISPOSAL (Check)	
LIVING UNITS	BEDROOMS	BATHS	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO				PUBLIC COMMUNITY INDIVIDUAL	
1	3	1 1/2							WATER SUPPLY BY SEWAGE DISPOSAL BY	
									XXXX XXXX	

**PART I—FOR USE OF INSPECTING OFFICIAL** (Fill in below information applicable to subject installation)

INSTRUCTIONS: If new installation, inspect for compliance with approved exhibits and record any observed information not shown on, or which varies from, the approved exhibits. If existing installation, furnish as much of the information as may be available. As applicable use inspector's sketch on reverse.

### INDIVIDUAL WATER SUPPLY SYSTEM

Distance to nearest public water main, 8 mi. feet. Size of main, \_\_\_\_\_ inches.

Individual wells  are  are not customary in neighborhood.

Give most recent record of failure of wells in immediate vicinity to furnish adequate supply of water \_\_\_\_\_

Properties in neighborhood  are  are not being developed with both individual water-supply and sewage-disposal systems.

Lot size: 121 feet wide, 100 feet deep. Dwelling set back from front property line, 35 feet.

Individual water supply from:  Drilled well.  Driven well.  Dug well.  Bored well.

Distance of well from: Community Supply Approved

Building foundation, \_\_\_\_\_ feet; nearest lot line at  front,  side,  rear, \_\_\_\_\_ feet;

cast iron sewer, \_\_\_\_\_ feet; tile sewer, \_\_\_\_\_ feet; septic tank, \_\_\_\_\_ feet; disposal field, \_\_\_\_\_ feet;

seepage pit, \_\_\_\_\_ feet; cesspool, \_\_\_\_\_ feet; other sources of possible pollution, \_\_\_\_\_ feet.

Well construction:

Diameter, \_\_\_\_\_ inches. Total depth, \_\_\_\_\_ feet. Type of casing, \_\_\_\_\_ Depth of casing, \_\_\_\_\_ feet.

Approximate depth of pumping level of water in well, \_\_\_\_\_ feet. Approximate yield, \_\_\_\_\_ gallons per minute.

Sealed watertight to depth of \_\_\_\_\_ feet.

Exterior space around casing sealed with:  Cement grout.  Puddled clay.  Ordinary backfill.

Well cover:  Concrete.  Wood.  Metal. Openings in well cover watertight:  Yes.  No.

Pump:  Shallow well.  Deep well. Length of drop pipe, \_\_\_\_\_ feet. Pump capacity, \_\_\_\_\_ gallons per minute.

Located in:  Basement.  Pump room off basement.  Pump house above ground.  Pump pit.

Pump room properly drained:  Yes.  No. Pump mounting watertight:  Yes.  No.

Type of storage:  Pressure.  Gravity. Capacity, \_\_\_\_\_ gallons.

Has bacteriological examination of water been made?  Yes.  No. If answer is "yes," give date \_\_\_\_\_, 19\_\_\_\_.

Quality of water  is  is not satisfactory for human consumption.

Installation  does  does not comply with approved exhibits, if any.

### INDIVIDUAL SEWAGE-DISPOSAL SYSTEM

PRIMARY TREATMENT consists of  Septic tank.  Cesspool.

Septic tank:

Distance from well, 1000+ feet. Material, Concrete Number of compartments 1

Total liquid capacity, 1000 gallons. Capacity inlet compartment, 1000 gallons.

Inside length, 8'10" feet. Inside width, 3'6" feet. Liquid depth, 5'0" feet.

Cesspool:

Distance from: Well, \_\_\_\_\_ feet; foundation, \_\_\_\_\_ feet; nearest lot line at  front,  side,  rear, \_\_\_\_\_ feet.

Inside diameter, \_\_\_\_\_ feet. Depth, \_\_\_\_\_ feet. Liquid capacity, \_\_\_\_\_ gallons. Lining material \_\_\_\_\_

SECONDARY TREATMENT consists of  Distribution box and  Tile disposal field.  Seepage pits. Other \_\_\_\_\_

Tile disposal field:

Distance from: Well, 1000+ feet; foundation, 25 feet; nearest lot line at  front,  side,  rear, 20 feet.

Total length of tile lines, 192 feet. Number of lines, 2. Distance between lines, 2 feet.

Total effective absorption area in bottom of trenches, 576 square feet. Trench width, 72 inches.

Length of each line, 96 feet. Depth, top of tile to finish grade, 24 inches.

Type of filter material:  Gravel.  Broken stone.  Cinders. Other \_\_\_\_\_

Depth of filter material beneath tile, 6 inches. Depth of filter material over tile, 2 inches.

Seepage pits:

Number of pits, \_\_\_\_\_ Outside diameter, \_\_\_\_\_ feet. Depth, \_\_\_\_\_ feet. Lining material \_\_\_\_\_

Distance from: Well \_\_\_\_\_ feet; foundation \_\_\_\_\_ feet; nearest lot line at  front  side  rear \_\_\_\_\_ feet