

PROPOSED INSTALLATION OF INDIVIDUAL SEWAGE-DISPOSAL AND/OR SUPPLY SYSTEM

Three copies must be completed and accompany each FHA application. After processing, one copy will be returned to the mortgagee and one copy to the local health department.

FHA CASE NUMBER _____

Name of Property Owner Wellco Contractors, Inc.

Property Address: Lot 141, Rolling Springs S/D
(If this property is in a development, give lot number and block number)

Number of bedrooms proposed 3. Approximate area of lot _____ square feet.

House is to be set back 35 feet from front boundary.

I propose to construct on the above-captioned property an individual type sewage-disposal system XX, well _____. This installation will be constructed so as to meet all the requirements of the local health department, the Federal Housing Administration and the State Board of Health.

The principal dimensions of these units are:

SEPTIC TANK: Working capacity 900 gallons.

Manufacturer (if precast) _____

N. C. State Board of Health Serial No. _____

NOTE: If tank has not been specifically approved by the State Board of Health, submit plans and specifications.

PERCOLATION TEST RESULTS (MPS 1103-10- minimum one per lot - others if results indicate necessity.)

Hole No. 1 18" 11" 4 (Minutes per inch of fall). 30 min.

SUBSURFACE ABSORPTION FIELD (MPS 1103-7 through 1103-7.14)

No. of trenches 1; total length 100 feet; width 72 inches;
total trench bottom area 600 sq. ft. (MPS Tables 11-4 and 11-7).

Is system to be installed to accommodate: Garbage Grinder Yes _____ No XX
Washing Machine Yes XX No. _____

WELL: Type Community Size of storage tank _____ (MPS 1102-7.1)
(Drilled, Driven, Bored, Dug)

Make: Type and capacity pump _____

DATE: August 8, 1974

William S. Wellons, Jr.
(Signature of Property Owner)

A representative of the Harnett County Health Department has inspected this site and finds it suitable for the proposed installation.

Would it be economically feasible to establish public or adequate community or sewage disposal facilities? Yes _____ No XX

Date: 8-12 Signed [Signature]

Title _____

If there is any pertinent information which the sanitarian desires to convey to the reviewing officials, which is not covered above, see the back of this application.

VETERANS ADMINISTRATION REPORT OF INSPECTION, INDIVIDUAL WATER SUPPLY AND SEWAGE-DISPOSAL SYSTEM

(TOP SECTION TO BE FILLED IN BY VA.)

REGIONAL OFFICE Veterans Administration 301 North Main Street Winston-Salem, N. C.	PROPERTY ADDRESS 6702 Azalea Drive Spring Lake, N. C. 28390	SUBDIVISION NAME Rolling Springs BLOCK NO. _____ LOT NO. 141
NAME OF BUILDER Welco Contractors, Inc. P. O. Box 766 Spring Lake, N. C. 28390	NAME OF LENDER First Atlantic Corporation P. O. Box 3362 Fayetteville, N. C. 28305	CASE NO. 240273 TYPE OF INSTALLATION <input checked="" type="checkbox"/> NEW <input type="checkbox"/> EXISTING

TOTAL NUMBER	BASEMENT	CAN ATTIC OR OTHER AREA BE MADE INTO ADDITIONAL BEDROOMS?	IF YES, HOW MANY?	WATER SUPPLY AND SEWAGE DISPOSAL (Check)			
LIVING UNITS	BEDROOMS	BATHS	<input type="checkbox"/> YES		PUBLIC	COMMUNITY	INDIVIDUAL
1	3	1 1/2	<input checked="" type="checkbox"/> NO	<input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		XX	XX
				WATER SUPPLY BY			
				SEWAGE DISPOSAL BY			XX

PART I—FOR USE OF INSPECTING OFFICIAL (Fill in below information applicable to subject installation)

INSTRUCTIONS: If new installation, inspect for compliance with approved exhibits and record any observed information not shown on, or which varies from, the approved exhibits. If existing installation, furnish as much of the information as may be available. As applicable use inspector's sketch on reverse.

INDIVIDUAL WATER SUPPLY SYSTEM

Distance to nearest public water main, 8 mi. feet. Size of main, _____ inches.

Individual wells are are not customary in neighborhood.

Give most recent record of failure of wells in immediate vicinity to furnish adequate supply of water _____

Properties in neighborhood are are not being developed with both individual water-supply and sewage-disposal systems.

Lot size: 99 feet wide, 100 feet deep. Dwelling set back from front property line, 35 feet.

Individual water supply from: Drilled well. Driven well. Dug well. Bored well.

Distance of well from: Community Supply Approved

Building foundation, _____ feet; nearest lot line at front, side, rear, _____ feet;

cast iron sewer, _____ feet; tile sewer, _____ feet; septic tank, _____ feet; disposal field, _____ feet;

seepage pit, _____ feet; cesspool, _____ feet; other sources of possible pollution, _____ feet.

Well construction:

Diameter, _____ inches. Total depth, _____ feet. Type of casing, _____ Depth of casing, _____ feet.

Approximate depth of pumping level of water in well, _____ feet. Approximate yield, _____ gallons per minute.

Sealed watertight to depth of _____ feet.

Exterior space around casing sealed with: Cement grout. Puddled clay. Ordinary backfill.

Well cover: Concrete. Wood. Metal. Openings in well cover watertight: Yes. No.

Pump: Shallow well. Deep well. Length of drop pipe, _____ feet. Pump capacity, _____ gallons per minute.

Located in: Basement. Pump room off basement. Pump house above ground. Pump pit.

Pump room properly drained: Yes. No. Pump mounting watertight: Yes. No.

Type of storage: Pressure. Gravity. Capacity, _____ gallons.

Has bacteriological examination of water been made? Yes. No. If answer is "yes," give date _____, 19____.

Quality of water is is not satisfactory for human consumption.

Installation does does not comply with approved exhibits, if any.

INDIVIDUAL SEWAGE-DISPOSAL SYSTEM

PRIMARY TREATMENT consists of Septic tank. Cesspool.

Septic tank:

Distance from well, 1000+ feet. Material, Concrete Number of compartments 1

Total liquid capacity, 1000 gallons. Capacity inlet compartment, 1000 gallons.

Inside length, 8'10" feet. Inside width, 3'6" feet. Liquid depth, 5 feet.

Cesspool:

Distance from: Well, ~~XXXXX~~ feet; foundation, _____ feet; nearest lot line at front, side, rear, _____ feet.

Inside diameter _____ feet. Depth, _____ feet. Liquid capacity, _____ gallons. Lining material _____

SECONDARY TREATMENT consists of Distribution box and Tile disposal field. Seepage pits. Other _____

Tile disposal field:

Distance from: Well, 1000+ feet; foundation, 25 feet; nearest lot line at front, side, rear, 20 feet.

Total length of tile lines, 192 feet. Number of lines, 2. Distance between lines, 2 feet.

Total effective absorption area in bottom of trenches, 576 square feet. Trench width, 72 inches.

Length of each line, 96 feet. Depth, top of tile to finish grade, 24 inches.

Type of filter material: Gravel. Broken stone. Cinders. Other _____

Depth of filter material beneath tile, 6 inches. Depth of filter material over tile, _____ inches.

Seepage pits:

Number of pits _____ Outside diameter, _____ feet. Depth, _____ feet. Lining material _____