SITE/SOIL EVALUATION FOR ON-SITE WASTEWATER

APPLICANT NAME _____ _____ DATE _____

FACTORS		PROFILES									
		1	2	3	4	5	6	7	8	9	10
LANDSCAPE POSITION	.1940	L	L	L							
SLOPE (%)	.1940	0 - 2									
HORIZON 1 DEPTH		0 - 4									
Texture Group	.1941(A)(1)	SCL-CL									
Consistence	.1941	FR									
Structure	.1941(A)(2)	2SBK									
Mineralogy	.1941(A)(3)	SSSP									
HORIZON 2 DEPTH		4 - 12									
Texture Group	.1941(A)(1)	LS									
Consistence	.1941	FR									
Structure	.1941(A)(2)	GR									
Mineralogy	.1941(A)(3)	NSNP									
HORIZON 3 DEPTH		12 - 36									
Texture Group	.1941(A)(1)	SL									
Consistence	.1941	FR									
Structure	.1941(A)(2)	GR									
Mineralogy	.1941(A)(3)	NSNP									
HORIZON 4 DEPTH		36 - 42									
Texture Group	.1941(A)(1)	SCL									
Consistence	.1941	FR									
Structure	.1941(A)(2)	GR									
Mineralogy	.1941(A)(3)	SSSP									
SOIL WETNESS	.1942	42"									
RESTRICTIVE HORIZON	.1944										
SAPROLITE	.1943/.1956										
CLASSIFICATION	.1948	PS									
LONG TERM ACCEPTANCE RATE	.1955	.5	.6	.5							