

REPAIR

HAMILTON COUNTY HEALTH DEPARTMENT  
ENVIRONMENTAL HEALTH SECTION

No 16146

# OPERATIONS PERMIT

Name: (owner) SAM STEED  New Installation  Septic Tank  
 Property Location: SR# RIVER RD  Repairs  Nitrification Line  
 Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
 TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
 Contractor: JOHNNY JONES Registration # \_\_\_\_\_

Basement with Plumbing:  Garage:

Water Supply:  Well  Public  Community

Distance From Well: \_\_\_\_\_ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other POLYSTYRENE AGGREGATE TRENCH

Size of tank: Septic Tank: EXIST. gallons Pump Tank: \_\_\_\_\_ gallons

Subsurface Drainage Field No. of ditches 3 exact length of each ditch 75 ft. width of ditches 3 ft. depth of ditches 24 in.

French Drain: \_\_\_\_\_ Linear feet

Date: 9/26/03  
 Inspected by: [Signature] Environmental Health Specialist

PERMIT NO. \_\_\_\_\_

