

SITE/SOIL EVALUATION
FOR
ON-SITE WASTE WATER

APPLICANT: Daniel Stephenson PHONE: _____ APPLICATION DATE: _____
 ADDRESS: _____
 COUNTY: Harnett PROPERTY SIZE: 3.3 Ac PROPOSED FACILITY: Home
 LOCATION OF SITE: Fred Burns Rd.
 WATER SUPPLY: On-Site Well _____ Community _____ Public L Other _____ EVALUATION BY: Auger Boring L Pit _____ Cu _____

FACTORS		PROFILES								
		1	2	3	4	5	6	7	8	9
LANDSCAPE POSITION	.1940	L	L	L	L					
SLOPE (%)	.1940	0-10	0-10	0-10	0-10					
HORIZON 1 DEPTH		0-12	0-12	0-15	0-12					
Texture Group	.1941(A)(1)	SCL	SCL	SCL	SC					
Consistence	.1941	Fr	Fr	Fv	F ₁					
Structure	.1941(A)(2)	wbK	wbK	wbK	sbK					
Mineralogy	.1941(A)(3)	1:1	1:1	1:1	1:1					
HORIZON 2 DEPTH		12-48	12-24	15-22	12-48					
Texture Group	.1941(A)(1)	S ₁ Cl	SC	CL	Cl to S ₁ Cl					
Consistence	.1941	F ₁	F ₁	F ₁	F ₁					
Structure	.1941(A)(2)	sbK	sbK	sbK	sbK					
Mineralogy	.1941(A)(3)	1:1	1:1	22-48	1:1					
HORIZON 3 DEPTH			24-48	S ₁ Cl						
Texture Group	.1941(A)(1)		CL	F ₁						
Consistence	.1941		F ₁	sbK						
Structure	.1941(A)(2)		sbK							
Mineralogy	.1941(A)(3)		1:1	1:1						
HORIZON 4 DEPTH										
Texture Group	.1941(A)(1)									
Consistence	.1941									
Structure	.1941(A)(2)									
Mineralogy	.1941(A)(3)									
SOIL WETNESS	.1942									
RESTRICTIVE HORIZON	.1944									
SAPROLITE	.1943/.1956									
CLASSIFICATION	.1948	ps	ps	ps	ps					
LONG TERM ACCEPTANCE RATE	.1955	.3	.4	.4	.3					

AVAILABLE SPACE (.1945): OK SITE LONG TERM ACCEPTANCE RATE: .35
 OTHER FACTORS (.1946): _____ SYSTEM TYPE: CONV
 SITE CLASSIFICATION (.1948): ps

EVALUATED BY: Jff Eudy OTHERS PRESENT: _____
 COMMENTS: _____

SITE PLAN APPROVAL

District **BA-40** Use **SFR**

Bedrooms **3**

10/6/95

DE.J

53°34'31" E

147.83'

M. Mahlke

Zoning Administrator

S 85°49'01"E

240.04'

EIS

THE LOT(S) ON THIS PLAN
CONSULTANT. BASED ON THE
THIS PLAN MEET APPROPRIATE
APPROVAL FOR EACH LOT RE
HARNETT COUNTY HEALTH DEPT
AND SITING IN ACCORDANCE
TIME OF PERMITTING. THIS
APPROVAL OR A PERMIT FOR

8-30-95

DATE

Robert E.ley
D.B. 834, Pg.
(1.679 Ac. Resid)

3.329 ACRES

(Tax Parcel # 05-0625-0010)

SFR

38'

42'

Driveway

140'

450.08'

N 86°19'07"W

3.25'

S 07°35'30"E 482.88' (Total)
383.24'

0.795 Ac. Total
0.171 Ac. R/W
0.624 Ac. Net
Tax Parcel #
05-0625-0015-01

S 28°1'55"E 372.32'
340.65'

ISS
Nail
Control Corner

L=242.39'
R=358.85'
(S 22°33'00"W)
(237.80')

ISS Road
(Public Dedicated)
S.R. 145

N 08°09'27"E
283.58'

0-12.55C
12-24.5C
12-48.7C
12-97.4C
24-48.8C
48-97.6C

Dorothy Burns