

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH SECTION

N008051

CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Nelson Currin/Ronald Byrd New Installation Septic Tank
Property Location: SR# 1552 Repairs Nitrification Line
Subdivision Grimesland Lot # 13
TAX ID# _____ Quadrant # _____
Contractor: McLamb Registration # _____

Basement with Plumbing: Garage:
Water Supply: Well Public Community
Distance From Well: > 50 ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system: Conventional Other _____
Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 85 ft. width of ditches 3 ft. depth of ditches 18-24 in.
French Drain: _____ Linear feet

PERMIT NO. 10406

Date: 10/20/94
Inspected by: Chris Carter, P.S.
Environmental Health Specialist

