

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No Person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Tracy Stephens

New Installation Septic Tank

Property Location: SR# 1505

Repairs Nitrification Line

Subdivision ANNIE Ruth Bell Lot # A

Tax ID # _____ Quadrant # _____

Number of Bedrooms Proposed: 3 Lot Size: 5.845

Basement with Plumbing: Garage:

Revised 9/8/03

Water Supply: Well Public Community

Distance From Well: 50' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system: Conventional Other _____

Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface Drainage Field: No. of ditches 2 of each ditch 150 ft. width of ditches 3 ft. depth of ditches 18-22 in.


French Drain Required: - Linear feet

Date: 4-13-98

This permit is subject to revocation if site plans or intended use change.

Signed: James E. Mantel, R.S.
Environmental Health Specialist

SR 1505 PEAKIDGE



HARNETT COUNTY HEALTH DEPARTMENT
AUTHORIZATION TO CONSTRUCT

Authorization is hereby given to construct a wastewater system to the specifications described by Harnett County Health Department Improvement Permit # 14709. This authorization shall be valid for a period not to exceed five (5) years from the date of issuance. This authorization will be invalid if ownership, site plans, or intended use change.

Owner or Authorized Agent Ruth Bell

Name: Tracey Stephenson Telephone # 941-0333

Address: 2484 Masse-gill Pond Angiers N.C.

Property Location: SR # 1505 Road Name Pearridge

New Installation Repair Septic Tank Nitrification Lines

Subdivision ANNEX Ruth Bell Lot # A

Number of Bedrooms Proposed: 3 Lot size: 5.845

Basement With Plumbing Without Plumbing

Water Supply: Well Public Minimum Well Setback: 50' ft.

Type of System: Conventional Other

Tank Volume: Septic Tank 1000 gallons Pump Chamber gallons

Nitrification Field Specifications

Number of fields 2 Number of Lines per Field 2 Length of lines 150

Width of ditches 3 ft. Depth of ditches 18-22 inches

French Drain: Linear feet required Depth of gravel

No wastewater system shall be covered or placed into use by any person until an inspection by the Harnett County Health Department has determined that the system has been installed according to the conditions of the improvement permit and that a valid operations permit has been issued.

Authorized Agent for Harnett County Health Department

Name: James E. Manhart P.E. RES. Date: 4-13-98