

IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Brantley & Sons Const. New Installation Septic Tank
 Property Location: SR 1440 Repairs Nitrification Line
Township Subdivision Lot 7

Number of Bedrooms Proposed: 3 Dish Washer Garbage Disposal
 Lot Size: 148 x 101 Water Supply: Well City Community
 Distance From Well?

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.


Kind of Material for Tank: Concrete Other _____

Size of Tank: Capacity 900 Gallons
 Subsurface Drainage Field Ditches: No. of 2 Exact Length of each Ditch 80 Ft. Width of Ditches 3 Ft. Depth of Ditches 22 Inches

Any Change in the layout of this system without prior approval of the issuing authority will result in this permit being void.

Date: 12/7/87
 Signed: Mike Euber, Soil Scientist
 (SANITARIAN)

Valid After 3 Years



- ① Stay 10ft. from prop. lines
- ② Garbage disposal not recommended