

COMMENTS:

12/18/14 Spoke with Mr. Butter. D-Box was not uncovered
uncovered. I told him to call Maples Septic & have them
give me a call & I would meet them out there to look at
the box & see if new drain lines were needed.

Or ~~we~~ we could use the system next door, temporarily

COMMENTS: _____

1/23/2015 Met with Maples Septic. The D-Box was crushed.

Maples replaced D-Box + "T".