

# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows:  
 Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department."

Name: (owner) Wayne Anderson Const.  New Installation  Septic Tank  
 Property Location: Mill Branch Subd.  Repairs  Nitrification Line  
lot 6

Number of Bedrooms Proposed: 3  Dish Washer  Garbage Disposal  
 Lot Size: 125' x 290' Water Supply:  Well  City  Community  
 Distance From Well?  100 ft

Above information certified by: Application

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Kind of Material for Tank:  Concrete  Other 1000 gal Pump Chamber

Size of Tank: Capacity 1000 Gallons  
 Subsurface No. of Exact Length Width of Depth of  
 Drainage Field Ditches 4 of each Ditch 90 Ft. Ditches 12" Ft. Ditches 18 Inches

Any Change in the layout of this system without approval of the issuing authority will result in this permit being void.

Date: 9/2/87  
 Signed: Mike Egan Soil Scientist  
 (SANITARIAN)

Void After 3 Years well

