

HTE# _____

Harris County Department of Public Health 19849

PERMIT # 24447

Operation Permit

New Installation Septic Tank Repair Nitrification Line Expansion

PROPERTY LOCATION: SR 1547 Carson Gregory

Name: (owner) DAVID BARNES SUBDIVISION _____ LOT # _____

System Installer: LARRY SHARPE Registration # _____

Basement with plumbing: Garage Number of Bedrooms 3-4 Future

Type of Water Supply: Community Public Well Distance from well _____ feet

System Type: 25% REDUCTION SYSTEM Type I B G 6-2 Lay Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.

* TANK WAS SET properly with fall to D-BOX.

* Full STORAGE ON DRAIN LINES achieved. D-BOX TO LINE WAS higher than 25% Red.

* System Ran For 24" x 18" X WAS LAID out to be 22" entire DRAIN length

* System OK - But NOT INSTALLED AS DIRECTED ON PREVIOUS day's CONSULTATIVE MEETING

* System WAS LAID out + Flagged with contractor on 2-13-08 AT 9:45 AM

SR-1547 Carson Gregory RD

PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other 25% REDUCTION SYSTEM Size of tank: Septic Tank: 1000 gallons Pump Tank: _____ gallons

Subsurface No. of _____ exact length _____ width of _____ depth of _____

Drainage Field ditches 2 of each ditch 150 feet ditches 3 feet ditches 24x18 inches

French Drain Required: _____ Linear feet

Authorized State Agent James E. Mansueti Date 2-14-08